



Italia

# COMPLIANCE

with IEC EN 61508

Certificate No.: C-IS-722221214

CERTIFICATE OWNER: KOSO PARCOL S.r.l. a socio unico  
Via Isonzo, 2  
20010, Canegrate (MI) - Italy

WE HEREWITH CONFIRM THAT  
CONTROL VALVES AND PNEUMATIC ACTUATORS  
MEET THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLES  
FOR THE SAFETY FUNCTION:

*For Control Valves: "Open and/or Close when required. In case of to Close Safety Function, valve leakage must be within limit values agreed with the Customer"*

*For Pneumatic Actuators: "Proper valve acting when required"*

Examination result:

The above reported Control Valves and Pneumatic Actuators were found to meet the standard defined requirements of the safety levels detailed in the following table (T-IS-722221214) according to IEC EN 61508, under fulfillment of the conditions listed in the Report R-IS-722221214 Rev.1 dated January, 28<sup>th</sup> 2021 in its currently valid version, on which this Certificate is based

Examination parameters:

Construction/Functional characteristics and reliability and availability parameters of the above Control Valves and Pneumatic Actuators

Official Report No.:

R-IS-722221214 Rev.1

Expiry Date

January, 27<sup>th</sup> 2024

IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN INTEGRAL PART OF THIS DOCUMENT  
THE PRESENT DOCUMENT SUBSTITUTES AND REPEALS THE DOCUMENT C-IS-722134012-01 REV.1

Reference Standard

IEC EN 61508:2010 Part 2, 4, 6, 7

Sesto San Giovanni, January, 28<sup>th</sup> 2021

TÜV ITALIA Srl

TÜV ITALIA Srl  
Industry Service Division  
Technical Manager

Paolo Marcone





Italia

## SUMMARY TABLE

T-IS-722221214

<i>E/EE/EP safety-related system (final element)</i>	<b>Control Valves produced by Koso Parcol S.r.l.</b>
<b>Models</b>	1-4*, 1-5*, 1-6*, 1-7*, 1-8*, 1-9*
<b>Size / Class</b>	½" ≤ NPS ≤ 28" ANSI 150 to ANSI 2500
<b>System type</b>	Type A
<b>Systematic Capability</b>	SC3
<b>Safety Function Definition</b>	"Open and/or Close when required. In case of to Close Safety Function, valve leakage must be within limit values agreed with the Customer"
<b>Max SIL<sup>(1)</sup></b>	<b>SIL3</b>
λ <sub>TOT</sub>	3,406E-08
λ <sub>NE</sub>	8,149E-09
λ <sub>S</sub>	0,000E+00
λ <sub>DD,PST<sup>(2)</sup></sub>	1,555E-08
λ <sub>DU,EPT</sub>	1,036E-08
<b>β and β<sub>D</sub> factor</b>	10%
<b>MRT</b>	8 h
<b>Hardware Safety Integrity</b>	Route 2 <sub>H</sub>
<b>Systematic Safety Integrity</b>	Route 2 <sub>s</sub>
<b>Remarks</b>	
(1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD <sub>AVG</sub> considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.	
(2) Considering an automatic Partial Stroke Test.	

SIL classification according to Standard IEC EN 61508 for Control Valves produced by Koso Parcol S.r.l.

T-IS-722221214

NOTE: The present table is integral part of the Document: C-IS-722221214

Date: January, 28<sup>th</sup> 2021



Italia

## SUMMARY TABLE

T-IS-722221214

<i>E/EE/EP safety-related system (final element)</i>	<b>Pneumatic Actuators produced by Koso Parcol S.r.l.</b>
<i>Models</i>	1-X-210, 1-X-250, 1-X-290
<i>Size</i>	250 mm ≤ DN ≤ 600 mm
<i>System type</i>	Type A
<i>Systematic Capability</i>	SC3
<i>Safety Function Definition</i>	“Proper valve acting when required”
<i>Max SIL<sup>(1)</sup></i>	<b>SIL3</b>
$\lambda_{TOT}$	2,572E-08
$\lambda_{NE}$	0,000E+00
	1,117E-08
$\lambda_S$	7,106E-09
$\lambda_{DD,PST}^{(2)}$	4,606E-09
$\lambda_{DU,EPT}$	2,844E-09
<i><math>\beta</math> and <math>\beta_D</math> factor</i>	10%
<i>MRT</i>	8 h
<i>Hardware Safety Integrity</i>	Route 2H
<i>Systematic Safety Integrity</i>	Route 2s
<b>Remarks</b>	
<p>(1) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of <math>PFD_{AVG}</math> considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.</p> <p>(2) Considering an automatic Partial Stroke Test.</p>	

SIL classification according to Standard IEC EN 61508 for Pneumatic Actuators produced by Koso Parcol S.r.l.

T-IS-722221214

NOTE: The present table is integral part of the Document: C-IS-722221214

Date: January, 28<sup>th</sup> 2021